

Pre Inspection Check List

- Do all the pool gates open away from the pool?
- Is the top of the gate latch 1500mm from the ground?
- When the gate is closed, is it securely locked or does it pull free easily?
- Does the gate self close from any position in its full arc of operation?
- Are the hinges 900mm apart? Or capped if less than 900mm apart?
- Is the gap under the fence less than 100mm?
- Is there a clear 300mm on the inside of the fence?
- Are all components on the gate and fence tight and secure?
(Including hinges, screws, latches & rails)
- Are there any gaps in the fence greater than 100mm?
- Can you create a gap in the fence greater than 105mm when you squeeze 2 rails together with 15kg of force?
- Are there any windows or louvers that provide access to the pool enclosure with gaps greater than 100mm?
- Is the fence a minimum 1200mm in height?
- Are there any climbable tree branches or stumps within 900mm of the outside of the fence?
- Are there any pot plants or climbable objects against the fence on either side?
- Are there any horizontal footholds on the fence greater than 10mm wide?
- Are the rails on the boundary fence more then 900mm from the top of the pool fence?
- Do you have a current CPR sign displayed that is unobstructed, clearly visible & undamaged?



0411 700 290



safetyfirst@poolsafetycertification.com.au

Lic No. 101297

